

MATERIALS REQUIRED FOR INSTALLATION

STANDARD 2" METER SETTING WITH BACKFLOW ASSEMBLY WITH 2" METER

<u>ITEM</u>	<u>REQ'D</u>	<u>SIZE</u>	<u>DESCRIPTION</u>
1	1	2"	METER BY C.W.D.
2	1	2"	APPROVED BACKFLOW ASSEMBLY, INCLUDING (2) BRASS GATE VALVES
3	2	2"	STREAMLINE HAND WHEEL GATE VALVES
4	2	1/2"	OVAL FLANGES, FEMALE
5	2	2"	STREAMLINE COUPLING, COPPER TO IRON, MALE
6	AS REQ'D	2"	COPPER TUBING - HARD
7	1lb.		SPECIAL SOLDER

(SEE DRAWING No. STD-M03 and STD-V01).
12-10-98