

MATERIAL REQUIRED FOR INSTALLATION

STANDARD 3" METER SETTING WITH 3" METER - FLANGED

<u>ITEM</u>	<u>Req'd</u>	<u>SIZE</u>	<u>DESCRIPTION</u>
1	1	2"	HAND WHEEL GATE VALVE, SCREWED
2	1	2" x 10"	BRASS NIPPLE
3	2	3"	HAND WHEEL GATE VALVES, FLANGED
4	1	3"	SWING GATE CHECK VALVE, FLANGED
5	1	2"	O.S.Y. VALVE, SCREWED
6	2	3" x 3" x 3"	TEE, FLANGED
7	2	2" x 6"	GALVANIZED NIPPLES
8	2	2" x 10"	GALVANIZED NIPPLE
9	2	2"	GALVANIZED ELBOWS-90 DEG.
10	2	2"	GALVANIZED STREET ELBOWS
11	1	2"	GALVANIZED UNION, MALE TO FEMALE
12	36"	2"	GALVANIZED PIPE, EXTRA HEAVY
13	1	3"	TURBINE METER <u>OR</u> COMPOUND METER METER & SPACER PROVIDED BY C.W.D.)
14	2	3"	BLIND FLANGES, DRILLED & TAPPED FOR 2" x 6" NIPPLES
15	1	2"	BRASS PLUG
16	10	3"	RING GASKETS
17	40	5/8" x 2-1/2"	MACHINE BOLTS
18	2	5/8" x 3"	STUD BOLTS
19	42	5/8"	HEX BOLTS

(SEE DRAWING STD-M06 & STD-M07 & STD-V01).

11-19-98